



**OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE,
BUXI BAZAR, CUTTACK, 753001.**

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017 r/w Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019.)

File No. X-2-B-17-2020

Certificate No. 17 /CR.CTC,

dated: 24.02.2021

This Certificate is valid up to 23.02.2023.

(Apply for renewal at least three months before expiry)


Certified that the Suddhananda Vidyalaya (G+2 Floor) School building, over plot no.260/1187, Khata no.372, Thana no.235, Mouza-Madhupur, Dist-Jagatsinghpur consisting of total 01 no. building was inspected by Officers of the Fire Service on 18.02.2021 in presence of Sri Biswajit Swain, Principal with team and it has been found to comply with the Fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules-2017 read with Fire Prevention and Fire Safety (Amendment) Rules-2019 and Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No.28550/CD, Bhubaneswar, dt.28.08.2020 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

01	Ground, 1 st and 2 nd floor	---Usage---	Educational (School)
----	---	-------------	-------------------------

CONDITIONS:

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organised at least once in six months by involving local Fire Station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of building/premises.
6. The plan needs to be regularized / approved by the competent plan approving authority of the jurisdiction as per Govt. Of Odisha Home Department notification No.28550/CD, Bhubaneswar, dt.28.08.2020 regarding one time relaxation scheme for Odisha Fire Service on requirement of structural Fire Safety parameters.
7. All other conditions furnished in Odisha Fire Service one time relaxation scheme published vide Govt. of Odisha Home Department Notification No.28550/CD, Bhubaneswar, dt.28.08.2020 will be applicable to this occupancy and applicant will comply on each point accordingly.
8. This fire safety Certificate do not absolve provisions made in any other rules and will not automatically immune the provisions made therein.

By order of the Director of Fire Service



(Trilok Kumar Babu)

Deputy Fire Officer,
Cuttack Circle, Cuttack


Name & Designation of the Issuing Officer:- Trilok Kumar Babu, Deputy Fire Officer

OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE,
POST BAGAR, CUTTACK, 753001


Memo No- 379 /CR.CTC.


Date-24/02/2021

Copy to Swami Atmananda Saraswati, Chairman, Suddhananda Vidyalaya, Jagatsinghpur for information and necessary action from your end.


24/02/2021

Deputy Fire Officer,
Cuttack Circle, Cuttack.


Principal
Suddhananda Vidyalaya
Jagatsinghpur


Secretary
Suddhananda Vidyalaya
Jagatsinghpur